

## HIGH EAVE (SCULPTURED)


- EH3010 - HIGH EAVE STRUT w WALL PANEL
  - EH3030 - HIGH EAVE w MASONRY WALL
  - EH3050 - HIGH EAVE GIRT w NO WALL PANEL
  - EH3051 - HIGH EAVE STRUT w NO WALL PANEL
  - EH3055 - HIGH EAVE GIRT w PARTIAL WALL PANEL
  - EH3056 - HIGH EAVE STRUT w PARTIAL WALL PANEL
  - EH3610 - HIGH EAVE STRUT w INSULATED WALL PANEL
-

## EH3010 - HIGH EAVE STRUT W/ WALL PANEL

[Download the DWG file by clicking here.](#)


### HIGH EAVE LAP & FLASHING BACKER

SLIDE FIELD CUT SECTION FLASHING ENDLAP BACKER ONTO THE LOWER TRIM PIECE. PLACE TAPE MASTIC NEXT TO HEM OF THE BACKER (NOT ON TOP OF HEM). APPLY CONTINUOUS BEAD OF CAULK 1" FROM END OF TRIM DOWN PROFILE OF TRIM. FASTEN LAP WITH STITCH FASTENERS AND POP RIVETS AS SHOWN.



FLASHING ENDLAP BACKER  
FIELD CUT FROM STANDARD FEB120

NOTE 1: REFERENCE DETAIL  
EA3076 FOR ADDITIONAL  
REQUIRED TRIM LAP FASTENER



### HIGH EAVE SCULPTURED DETAIL

HIGH EAVE SCULPTURED DETAIL w/ WALL PANELS  
SEE WALL SHEETING ERECTION NOTES FOR WALL PANEL FASTENER LOCATIONS

**EH3010**

### Detailer Notes:

- 1) CLOSURES HIGH EAVE LAYER DEFAULT IS ON. LAYER MUST BE TURNED OFF IF CLOSURES ARE NOT REQUIRED.
- 2) THIS STANDARD DETAIL IS APPROVED FOR MIAMI-DADE USE. ALTERATIONS TO THIS DETAIL MAY IMPACT APPROVAL.








## EH3055 - HIGH EAVE GIRT W/ PARTIAL WALL PANEL


[Download the DWG file by clicking here.](#)

### HIGH EAVE LAP & FLASHING BACKER

SLIDE FIELD CUT SECTION FLASHING ENDLAP BACKER ONTO THE LOWER TRIM PIECE. PLACE TAPE MASTIC NEXT TO HEM OF THE BACKER (NOT ON TOP OF HEM). APPLY CONTINUOUS BEAD OF CAULK 1" FROM END OF TRIM DOWN PROFILE OF TRIM. FASTEN LAP WITH STITCH FASTENERS AND POP RIVETS AS SHOWN.



**NOTE 1: REFERENCE DETAIL**  
**EA3076 FOR ADDITIONAL**  
**REQUIRED TRIM LAP FASTENER**



### HIGH EAVE SCULPTURED DETAIL

HIGH EAVE SCULPTURED DETAIL w/ PARTIAL WALL PANELS

**EH3055**

#### Detailer Notes:

- 1) THIS STANDARD DETAIL IS APPROVED FOR MIAMI-DADE USE. ALTERATIONS TO THIS DETAIL MAY IMPACT APPROVAL.




## EH3610 - HIGH EAVE STRUT W/ INSULATED WALL PANEL

[Download the DWG file by clicking here.](#)


### HIGH EAVE LAP & FLASHING BACKER

SLIDE FIELD CUT SECTION FLASHING ENDLAP BACKER ONTO THE LOWER TRIM PIECE. PLACE TAPE MASTIC NEXT TO HEM OF THE BACKER (NOT ON TOP OF HEM). APPLY CONTINUOUS BEAD OF CAULK 1" FROM END OF TRIM DOWN PROFILE OF TRIM. FASTEN LAP WITH STITCH FASTENERS AND POP RIVETS AS SHOWN.



IMP THICKNESS	ROOF SLOPE					
	1	2	3	4	5	6
2"	6"	6"	6"	7"	8"	9"
2.5"	6"	6"	6"	7"	8"	9"
3"	6"	6"	6"	7"	8"	9"
4"	6"	6"	6"	6"	6"	6"
5"	5"	5"	5"	5"	5"	5"
6"	4"	4"	4"	4"	4"	4"

**NOTE 1: REFERENCE DETAIL**  
**EA3076 FOR ADDITIONAL**  
**REQUIRED TRIM LAP FASTENER**



### HIGH EAVE SCULPTURED DETAIL

HIGH EAVE SCULPTURED DETAIL w/ WALL PANELS  
SEE WALL SHEETING ERECTION NOTES FOR WALL PANEL FASTENER LOCATIONS

**EH3610**

### Detailer Notes:

- 1) THIS STANDARD DETAIL IS APPROVED FOR MIAMI-DADE USE. ALTERATIONS TO THIS DETAIL MAY IMPACT APPROVAL.